

CERTIFICATE OF COMPLIANCE

Certificate Number 20140422-EX26464
Report Reference EX26464-20140418
Issue Date 2014-APRIL-22


Issued to: UTKARSH TUBES & PIPES LTD
23A, Netaji Subhas road, 5th floor, Suite22,
kolkata Westbengal 700001 INDIA

**This is to certify that
representative samples of** METALLIC SPRINKLER PIPE
See Next page for Models


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852 - Metallic Sprinkler Pipe for Fire Protection Service
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140422-EX26464
Report Reference EX26464-20140418
Issue Date 2014-APRIL-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Schedule 40 steel sprinkler pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2 and 4, 5, 6, 8, 10 and 12 in sizes, as per ASTM A53/A53M, Grade A and Grade B, Type E.

Schedule 30 steel sprinkler pipe in the 8, 10 and 12 in sizes, as per ASTM A53/A53M, Grade A and Grade B, Type E.

Schedule 20 steel sprinkler pipe in the 8, 10 and 12 in sizes, as per ASTM A53/A53M, Grade A and Grade B, Type E.


Schedule 40 steel sprinkler pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5 and 6 in size as per ASTM A795/A795M, Grade A and Grade B, Type E

Schedule 30 steel sprinkler pipe in the 8 and 10 sizes as per ASTM A795/A795M, Grade A and Grade B, Type E.

Schedule 10 steel sprinkler pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5 and 6 in sizes, as per ASTM A795/A795M, Grade A and Grade B, Type E.

All the above pipes are ERW and are constructed from hot rolled steel coils that conform to ASTM standards as indicated above.

All pipes with threaded ends shall conform to ANSI B1.20.1.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

